

System Usage	2023	2022
June	7,140,000	7,270,000
Daily Average	238,000	242,333
Max Daily	340,000	420,000
Year to Date	36,500,000	36,531,000

1. The service line leak at 33 Burpee Hill Rd. has not been repaired yet due to weather. Micah was able to run a temporary line over ground to bypass the leak for the time being.
2. Jon has finished all private flushing and Rhonda has billed all hydrants public and private.
3. Barrie Miller's Well Service returned Vertical Turbine #2 and installed it. The Allen Bradley VFD was not functioning at the time of installation for unknown reasons. The only thing I can surmise is, when the VFDs are powered down for an extended period of time, the computer cards get wiped. New cards were ordered for the VFD and Turbine #2 was put in to service. Last night Turbine #2 tripped out on a ground fault alarm. Luke from Barrie Miller's will be here in the morning.
4. I called Adam Ricker today to see if he had any updates on current projects. The only item of note is that Continuum is seeking a zoning variance from the Planned Unit Development section that requires them to be on municipal water and sewer.
5. Quarterly reports are done and have been sent into DES.
6. A&D Instruments had quoted us \$33,000.00 to upgrade each of the main SCADA PLCs. I called them today to update the quote and get back to me so that we can get that started. They will also be sending Matt out to check on our tank communication issue soon.

**Workload**

Backflow Testing ✓

Gate Box Repairs

Curb Stop Repairs

Respectfully Submitted,



Rob Thorp