

Commissioners  
Superintendent's Report

August 7, 2023

System Usage	2023	2022
July	7,760,000	9,620,000
Daily Average	250,322	310,322
Max Daily	360,000	420,000
Year to Date	44,260,000	46,151,000

1. We have been working with Micah Seneca at the Booster Station installing a chlorine analyzer line. We got the tough part done which was tapping the tank fill line that was ten feet deep. Micah will be back again this week to finish getting the line into the building.
2. We have been having issues with the chlorine system at Colby Point. We ended up replacing the chlorine pump with our spare which seems to have fixed the problem. Tech support for Prominent Pumps should be getting back to me soon about rebuilding the old pump. This pump was in constant service for about fifteen years.
3. Barrie Miller should have Vertical Turbine #2 motor back to us this week. Barrie and the motor shop believe the pump took a lightning strike. Rhonda has submitted paperwork for an insurance claim.
4. Colby Sawyer has approached me about parking in the field where the Booster Tank is located. I told them that I did not see a problem if the tank area itself is not used.
5. Rhonda got the energy audit scheduled for August 17<sup>th</sup>.
6. A&D Instruments sent Matt up to look at our communication issue with the tank. He was able to adjust the sensitivity of the radios and we have not had an issue since. I also gave A&D Instrument the go ahead to order the new PLCs for Colby Point and the Booster Station SCADA panels.
7. EJP is unable to get us 5/8"x 3/4" SRII meters because of an issue at the factor. They can get us I-Pearl meters or straight 5/8" meters. I was wondering what the Commissioners thoughts were.

**Workload**

Backflow Testing  
TTHM HAA5 Sampling  
Booster Station

Respectfully Submitted,



Rob Thorp