

System Usage	2026	2025
March	7,227,012	6,300,000
Daily Average	233,129	203,225
Max Daily	439,957	290,000
Year to Date	19,203,624	17,990,000

1. We were able to borrow the Town of New London's Auto Gun and pair it with our handheld meter reader. Tony has begun meter reading.
2. Meter replacements are complete for the year. Maggi, Tony, and Micah did an excellent job getting this done.
3. I had A&D Instruments here today to install our new alarm system.
4. I have provided you with a quote from A&D Instruments to perform preventive maintenance on the communications system on top of the tank. We have been without communication with the tank all winter and running on the backup system which only allows one pump to run at a time. I would like to get this work done before we get into the summer months.
5. We dealt with five water leaks last month. One on the main line to town near Camp Wallula. The next was at the New London DPW while we were repairing the first. St. Andrews Church had a leak in their crawl space which filled and flooded the adjoining basement. We had to dig the curb stop at St. Andrews to shut it off. There was a service line leak at Highland Ridge which Micah Seneca repaired on his own. Finally, I meter assembly blew off the line of a customer's house on County Rd. I called Tony out to this, and he was able to shut off the curb stop.
6. Quarterly reports are done and have been submitted to DES.


Workload

Backflow Testing

Quarterly Sampling

Equipment Maintenance

Respectfully Submitted,



Rob Thorp