

System Usage	2026	2025
May	7,688,873	6,520,000
Daily Average	248,028	210,322
Max Daily	413,313	360,000
Year to Date	33,389,236	31,040,000

1. Well 6 is back online and the lower three wells have been cleaned.
2. All summer services have been turned on and meters installed.
3. A&D instruments are on the schedule for June 18th to fix the tank communications issue.
4. There was a service line leak at 151 Job Seamans Acres. Micah Seneca repaired.
5. The pressure test at the Montessori School passed. The line was then chlorinated. They flushed and sampled for bacteria today.
6. Micah Seneca has started the service line identification and will continue on this through the summer months
7. I have been in contact with DN Tank to get on the schedule for the tank repair. He is sending a contract however, I will have a conversation with him before work begins regarding whether or not that drip ring return even needs to be there.

Workload

Backflow Testing
Curb and Gate Repairs
Main Flushing
Service Line ID

Respectfully Submitted,


Rob Thorp