

Commissioners  
Superintendent's Report

December 8, 2025

| System Usage  | 2025       | 2024       |
|---------------|------------|------------|
| November      | 6,380,211  | 5,810,000  |
| Daily Average | 212,674    | 193,666    |
| Max Daily     | 419,461    | 310,000    |
| Year to Date  | 84,990,581 | 76,137,000 |

1. A&D Instruments performed our annual meter calibration and performed maintenance on our process equipment.
2. MidCo Diving cleaned and inspected the tanks. There was nothing of note with the cleaning and inspection however, I did notice some of the overhang is falling off on the back side. I will call DN Tank to see if there is any kind of warranty or get a quote on repairing.
3. There was a water main leak at the New London DPW. This is the third leak on this ductile iron main since 2019. I believe it is due to electrolysis. The electrical system for the DPW garage is grounded to the main. Sam Clarke said that he will have Irish Electric take a look at this. The valve on this line needs to be replaced as well. We will schedule this for next summer.
4. Tony passed both his Grade I Treatment and Grade II Distribution exams.

**Workload**

Backflow Testing  
Meter Chang Outs

Respectfully Submitted,

  
Rob Thorp